

COMPRESSED GAS CYLINDER - EQUIPMENT INSPECTION



An equipment inspection checklist form designed for compressed gas cylinder assets.

* Your Name	* Date / Time

INSPECTION DETAILS

* Location	* Date of Inspection

INSPECTION CHECKLIST

* Are cylinders with a water weight capacity over 30 pounds equipped with means for connecting a valve protector device or with a collar or recess to protect the valve? <input type="checkbox"/> Sat (1/1) <input type="checkbox"/> Unsat (0/1) <input type="checkbox"/> NA	* Are cylinders legibly marked to clearly identify the gas contained? <input type="checkbox"/> Sat (1/1) <input type="checkbox"/> Unsat (0/1) <input type="checkbox"/> NA
* Are compressed gas cylinders stored in areas which are protected from external heat sources such as flame impingement, intense radiant heat, electric arcs or high temperature lines? <input type="checkbox"/> Sat (1/1) <input type="checkbox"/> Unsat (0/1) <input type="checkbox"/> NA	* Are cylinders located or stored in areas where they will not be damaged by passing or falling objects or subject to tampering by unauthorized persons? <input type="checkbox"/> Sat (1/1) <input type="checkbox"/> Unsat (0/1) <input type="checkbox"/> NA

COMPRESSED GAS TRANSPORTATION

* Are cylinders stored or transported in a manner to prevent them from creating a hazard by tipping, falling or rolling? <input type="checkbox"/> Sat (1/1) <input type="checkbox"/> Unsat (0/1) <input type="checkbox"/> NA	* Are cylinders containing liquefied fuel-gas stored or transported in a position so that the safety relief device is always in direct contact with the vapor space in the cylinder? <input type="checkbox"/> Sat (1/1) <input type="checkbox"/> Unsat (0/1) <input type="checkbox"/> NA
* Are valve protectors always placed on cylinders when the cylinders are not in use or connected for use? <input type="checkbox"/> Sat (1/1) <input type="checkbox"/> Unsat (0/1) <input type="checkbox"/> NA	* Are all valves closed off before a cylinder is moved, when the cylinder is empty and at the completion of each job? <input type="checkbox"/> Sat (1/1) <input type="checkbox"/> Unsat (0/1) <input type="checkbox"/> NA
* Are low pressure fuel-gas cylinders checked periodically for corrosion, general distortion, cracks or any other defect that might indicate a weakness or render it unfit for service? <input type="checkbox"/> Sat (1/1) <input type="checkbox"/> Unsat (0/1) <input type="checkbox"/> NA	* Does the periodic check of low pressure fuel-gas cylinders include a close inspection of the cylinders' bottom? <input type="checkbox"/> Sat (1/1) <input type="checkbox"/> Unsat (0/1) <input type="checkbox"/> NA

SUMMARY

Comments / Notes

Inspector Signature
